

Lead in drinking water tracking

< means no trace amounts of lead were detected.

| Outlet Number | Location | Sample Drawn | Sample Result (ppb) | Sample Tested | Planned Remediation |
|------------------|----------------------------|--------------|---------------------|---------------|--------------------------------|
| 376178 394662 | Lakes Youth Room | 11/9/22 | 5.18 | 12/12/22 | Initial |
| | | 5/4/23 | 1.98 | 6/6/23 | 2 nd sample - Flush |
| 376179 394664 | Lakes bathroom | 11/9/22 | 1.55 | 12/12/22 | Initial |
| | | 5/4/23 | < | 6/6/23 | 2 nd sample - Flush |
| 376180 394682 | Lakes fountain | 11/9/22 | 2.57 | 12/12/22 | Initial |
| | | 5/4/23 | < | 5/30/23 | 2 nd sample-Flush |
| 376177 | Oakdale Kitchen sink | 11/9/22 | < | 12/12/22 | N/A |
| 376181 | Oakdale boys bathroom sink | 11/9/22 | < | 12/12/22 | N/A |
| 378458 | Newport kitchen sink | 11/23/22 | 4.91 | 12/20/22 | Initial |
| | | 394670 | 1.32 | 6/6/23 | 2 nd sample - Flush |
| 378459 | Newport fountain | 11/23/22 | < | 12/20/22 | N/A |
| 376200 394674 | 101/102 craft room | 1/12/23 | 3.34 | 1/31/23 | Initial |
| | | 5/4/23 | < | 5/30/23 | 2 nd sample - Flush |
| | 101 bathroom | 12/20/23 | < | 1/10/24 | Initial |
| | | 12/20/23 | < | 1/10/24 | Flush |
| 376201 | 102 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376202 | 103 bathroom | 1/12/23 | < | 1/31/203 | N/A |
| 376203 394676 | 103/104 craft room | 1/12/23 | 1.83 | 1/31/23 | Initial |
| | | 5/4/23 | < | 5/30/23 | 2 nd sample - Flush |
| 376204 | 104 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376205 | 105 bathroom | 1/12/23 | < | 1/31/23 | N/A |

Upon request this document will be made available in alternate formats.

AN EQUAL OPPORTUNITY EMPLOYER

| | | | | | |
|------------------|------------------------------|-------------------|--------------|--------------------|---|
| 376206 394678 | 105/106 craft room | 1/12/23 5/4/23 | 1.70 < | 1/31/23 5/30/23 | Initial 2 nd sample - Flush |
| 376207 | 106 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376327 | 107 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376330 | 107/108 craft room | 1/12/23 | < | 1/31/23 | N/A |
| 376333 | 108 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376339 | 114 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376345 | 115 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376343 | 114/115 craft room | 1/12/23 | < | 1/31/23 | N/A |
| 376355 | 116 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376357 | 117 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376356 | 116/117 craft room | 1/12/23 | < | 1/31/23 | N/A |
| 376194 | 118 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376192 | 119 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376193 | 118/119 craft room | 1/12/23 | < | 1/31/23 | N/A |
| 376191 | 120 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376189 | 121 bathroom | 1/12/23 | < | 1/31/23 | N/A |
| 376190 394680 | 120/121 craft room | 1/12/23 5/4/23 | 1.25 1.03 | 1/31/23 5/30/23 | Initial 2 nd sample - Flush |
| 376188 | Staff lounge coffee maker | 1/12/23 | < | 1/31/23 | N/A |
| 376528 | Staff lounge sink | 1/12/23 | < | 1/31/23 | N/A |
| 376187 | Fountain by 108 | 1/12/23 | < | 1/31/23 | N/A |

Upon request this document will be made available in alternate formats.

AN EQUAL OPPORTUNITY EMPLOYER

| | | | | | |
|--------|-------------------------|---------|------|---------|--------------------------------|
| 376186 | Fountain by ED #1 | 1/12/23 | < | 1/31/23 | N/A |
| 376185 | Fountain by ED #2 | 1/12/23 | < | 1/31/23 | N/A |
| 376530 | Fountain by 115 #1 wall | 1/12/23 | < | 1/31/23 | N/A |
| 376184 | Fountain by 115 #2 | 1/12/23 | < | 1/31/23 | N/A |
| 376183 | Kettle cooker kitchen | 1/12/23 | < | 1/31/23 | N/A |
| 376182 | Prep sink kitchen | 1/12/23 | 2.01 | 1/31/23 | Initial |
| 394668 | | 5/3/23 | < | 6/6/23 | 2 nd sample - Flush |
| 390103 | CB Infant sink | 3/15/23 | < | 4/6/23 | N/A |
| 390102 | CB Toddler sink | 3/15/23 | < | 4/6/23 | N/A |
| 390101 | CB Kitchen | 3/15/23 | 4.04 | 4/6/23 | Initial |
| 394666 | | 5/4/23 | < | 6/6/23 | 2 nd sample - Flush |

Upon request this document will be made available in alternate formats.

AN EQUAL OPPORTUNITY EMPLOYER